

City of Naperville LED Test Site Meter Reading

<u>Installed meters 6/8/09</u>			<u>Monthly Consumption</u>		<u>Monthly Savings</u>
<u>Reading #1</u>	<u>LED South</u>	<u>HPS North</u>	<u>LED</u>	<u>HPS</u>	
<u>7/5/2009</u>	00255 KWH 1.07 KW	00618 KWH 2.60 KW			
<u>Reading #2</u>	<u>LED South</u>	<u>HPS North</u>			
<u>8/17/2009</u>	00660 KWH 1.07 KW	01610 KWH 2.61 KW	405	992	59.2%
<u>Reading #3</u>	<u>LED South</u>	<u>HPS North</u>			
<u>9/8/2009</u>	00902 kwh 1.07 kw	02194 kwh 2.59kw	242	584	58.6%
<u>Reading #4</u>	<u>LED South</u>	<u>HPS North</u>			
<u>10/09/2009</u>	01284 kwh 1.07 kw	03086 kwh 2.57kw	382	892	57.2%